



Water Quality Parameter Monitoring Form

Lead & Copper Rule Corrosion Control

County: Tillamook

Agency: Region 1

ENTRY POINT

EP- A

Day	pH	Alk	Phos	Sili	Y/N	<< Have minimums been met for this day?	PWS ID: 41	0	0	8	9	3
1	8.09				Y							
2	8.07				Y							
3	8.63				Y							
4	8.10				Y		System Name:	Tillamook Water Dept, City of				
5	8.22				Y							
6	8.19				Y		Sample Period	September 2022				
7	8.33				Y			Month/Year				
8	8.44				Y							
9	8.37				Y							
10	8.35				Y		Number of excursions* during this month:	0				
11	8.54				Y		(Over 9 excursions in 6 months is a violation.					
12	8.33				Y		Entry Point and Distribution excursions are					
13	8.17				Y		Cumulative). An 'excursion' is any day in which the					
14	8.24				Y		water quality parameter(s) fall below the minimum					
15	8.02				Y		set by the State					
16	8.06				Y							
17	8.06				Y							
18	8.16				Y							
19	8.13				Y							
20	8.04				Y							
21	7.99				Y							
22	7.97				Y		Minimum Water Quality Parameters as set by State:					
23	7.97				Y							
24	7.96				Y		pH	7.2				
25	8.00				Y		Alk	20				(Alkalinity)
26	7.96				Y							
27	7.98				Y							
28	8.07				Y							
29	7.98				Y							
30	7.98				Y		Print Name:	Levi Beachy				
31					Y		Signature:					
=N=Excursion) Total N's						0	Date:	October 4, 2022				

Send to DHS within 10 days after end of sampling period

OHA Drinking Water Program, PO Box 14350, Portland, OR 97293-0350

Phone (971) 673-0405 Website: <http://healthoregon.org/dwp/>