



Water Quality Parameter Monitoring Form

Lead & Copper Rule Corrosion Control

County: Tillamook

Agency: Region 1

ENTRY POINT

EP- A

Day	pH	Alk	Phos	Sili	Y/N
1	7.80				Y
2	7.84				Y
3	7.86				Y
4	7.95				Y
5	7.90				Y
6	7.90				Y
7	7.89				Y
8	7.88	28			Y
9	7.84				Y
10	7.91				Y
11	7.94				Y
12	7.95				Y
13	8.03				Y
14	8.07	25			Y
15	8.03				Y
16	8.05				Y
17	8.11				Y
18	8.17				Y
19	8.08				Y
20	8.10				Y
21	8.08	26			Y
22	8.34				Y
23	8.25				Y
24	8.07				Y
25	8.07				Y
26	8.37				Y
27	8.24				Y
28	8.36				Y
29	8.08				Y
30	8.12				Y
31					

<< Have
minimums
been met
for this day?

PWS ID: 41

System Name: Tillamook Water Dept, City of

Sample Period November 2022
Month/Year

Number of excursions* during this month: 0
(Over 9 excursions in 6 months is a violation.
Entry Point and Distribution excursions are
Cumulative). An 'excursion' is any day in which the
water quality parameter(s) fall below the minimum
set by the State

**Minimum Water Quality
Parameters as set by State:**

pH
Alk (Alkalinity)

Print Name: Levi Beachy

Signature:

Date: December 6, 2022

=N=Excursion) **Total N's**

Send to DHS within 10 days after end of sampling period

OHA Drinking Water Program, PO Box 14350, Portland, OR 97293-0350

Phone (971) 673-0405 Website: <http://healthoregon.org/dwp/>