



Water Quality Parameter Monitoring Form

Lead & Copper Rule Corrosion Control

County: Tillamook

Agency: Region 1

ENTRY POINT

EP- A

Day	pH	Alk	Phos	Sili	Y/N	<< Have
1	8.17				Y	minimums
2	8.03				Y	been met
3	8.39				Y	for this day?
4	8.09				Y	
5	8.07				Y	
6	8.10				Y	
7	8.04				Y	
8	8.14	23			Y	
9	9.41				OFF	
10	9.46				OFF	
11	9.41				OFF	
12	9.34				OFF	
13	9.26	24			Y	
14	8.56				Y	
15	8.30				Y	
16	8.09				Y	
17	8.10				Y	
18	8.08				Y	
19	8.14				Y	
20	8.30	31			Y	
21	10.08				Y	
22	8.25				Y	
23	8.38				Y	
24	8.23				OFF	
25	8.24				OFF	
26	8.22				Y	
27	8.20	26			Y	
28	7.50				Y	
29	8.30				OFF	
30	8.32				OFF	
31	8.40				OFF	

PWS ID: 41

0 0 8 9 3

System Name: Tillamook Water Dept, City of

Sample Period: December 2022
Month/Year

Number of excursions* during this month: 0
(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are Cumulative). An 'excursion' is any day in which the water quality parameter(s) fall below the minimum set by the State

Minimum Water Quality Parameters as set by State:

pH 7.2
Alk 20 (Alkalinity)

=N=Excursion) Total N's 0

Print Name: Levi Beachy
Signature:
Date: January 3, 2023

Send to DHS within 10 days after end of sampling period

OHA Drinking Water Program, PO Box 14350, Portland, OR 97293-0350

Phone (971) 673-0405 Website: <http://healthoregon.org/dwp/>