



Water Quality Parameter Monitoring Form

# Lead & Copper Rule Corrosion Control

County: Tillamook

Agency: Region 1

**ENTRY POINT**

**EP- A**

Day	pH	Alk	Phos	Sili	Y/N
1	8.15				Y
2	8.11				Y
3	8.08				Y
4	8.27				Y
5	8.19				Y
6	7.87	23			Y
7	8.43				Y
8	8.03				Y
9	8.22				Y
10	8.51				Y
11	8.16				Y
12	8.14				Y
13	7.35	23			Y
14	8.07				Y
15	8.15				Y
16	8.11				Y
17	8.03				Y
18	8.31				Y
19	8.00				Y
20	8.40				Y
21	7.36	20			Y
22	8.06				Y
23	8.47				Y
24	8.10				OFF
25	8.10				Y
26	8.06				Y
27	7.96				Y
28	7.51	20			Y
29					
30					
31					

<< Have minimums been met for this day?

PWS ID: 41

**System Name:** Tillamook Water Dept, City of

**Sample Period:** February 2023  
Month/Year

**Number of excursions\* during this month:** 0  
( Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are Cumulative). An 'excursion' is any day in which the water quality parameter(s) fall below the minimum set by the State

**Minimum Water Quality Parameters as set by State:**

pH

Alk  (Alkalinity)

**Print Name:** Levi Beachy  
**Signature:**   
**Date:** March 8, 2023

=N=Excursion) Total N's

Send to DHS within 10 days after end of sampling period

OHA Drinking Water Program, PO Box 14350, Portland, OR 97293-0350

Phone (971) 673-0405 Website: <http://healthoregon.org/dwp/>