



Water Quality Parameter Monitoring Form

Lead & Copper Rule Corrosion Control

County: Tillamook

Agency: Region 1

ENTRY POINT

EP- A

Day	pH	Alk	Phos	Sili	Y/N	<< Have been met for this day?	PWS ID: 41	<input type="text" value="0"/> <input type="text" value="0"/> <input type="text" value="8"/> <input type="text" value="9"/> <input type="text" value="3"/>						
1	8.46				Y									
2	8.16				Y									
3	8.18				Y									
4	8.13				Y		System Name:	Tillamook Water Dept, City of						
5	8.53				Y		Sample Period	May 2024						
6	8.68				Y									
7	8.96	22			Y									
8	8.16				Y									
9	8.12				Y									
10	8.08				Y		Number of excursions* during this month:							0
11	8.06				Y		<i>(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are Cumulative). An 'excursion' is any day in which the water quality parameter(s) fall below the minimum set by the State</i>							
12	8.25				Y									
13	8.04	21			Y									
14	8.14				Y									
15	8.16				Y									
16	8.17				Y									
17	8.13				Y									
18	8.18				Y									
19	8.30				Y									
20	8.64	23			Y									
21	8.19				Y									
22	8.15				Y									
23	8.14				Y									
24	8.23				Y									
25	8.56				Y									
26	8.45				Y									
27	8.23				Y									
28	8.30	23			Y									
29	8.61				Y									
30	8.24				Y		Print Name:	Levi Beachy						
31	8.22				Y		Signature:							

System Name: Tillamook Water Dept, City of

Sample Period May 2024
Month/Year

Minimum Water Quality Parameters as set by State:

pH

Alk (Alkalinity)

=N=Excursion) Total N's

Date: June 5, 2024

* Fawcett intake brought back online

Send to DHS within 10 days after end of sampling period

OHA Drinking Water Program, PO Box 14350, Portland, OR 97293-0350

Phone (971) 673-0405 Website: <http://healthoregon.org/dwp/>