



Water Quality Parameter Monitoring Form

Lead & Copper Rule Corrosion Control

County: Tillamook

Agency: Region 1

ENTRY POINT

EP- A

Day	pH	Alk	Phos	Sili	Y/N
1	7.70				Y
2	7.59				Y
3	7.68				Y
4	8.03				Y
5	8.31				Y
6	8.22				Y
7	8.08	23			Y
8	8.49				Y
9	8.53				Y
10	8.66				Y
11	8.42				Y
12	8.48				Y
13	8.34				Y
14	7.71	35			Y
15	8.72				Y
16	8.71				Y
17	8.57				Y
18	8.69				Y
19	8.48				Y
20	8.52				Y
21	8.54	20			Y
22	8.73				Y
23	8.69				Y
24	8.52				Y
25	9.05				Y
26	9.13				Y
27	9.58				Y
28	8.11	21			Y
29	8.25				Y
30	9.39				Y
31	9.46				Y

<< Have
minimums
been met
for this day?

PWS ID: 41


System Name: Tillamook Water Dept, City of

Sample Period October 2024
Month/Year

Number of excursions* during this month: 0
(Over 9 excursions in 6 months is a violation.
Entry Point and Distribution excursions are
Cumulative). An 'excursion' is any day in which the
water quality parameter(s) fall below the minimum
set by the State

**Minimum Water Quality
Parameters as set by State:**

pH	<input type="text" value="7.2"/>	
Alk	<input type="text" value="20"/>	(Alkalinity)

Print Name: Levi Beachy
Signature: 
Date: November 4, 2024

=N=Excursion) **Total N's**

Send to DHS within 10 days after end of sampling period

OHA Drinking Water Program, PO Box 14350, Portland, OR 97293-0350

Phone (971) 673-0405 Website: <http://healthoregon.org/dwp/>