



Water Quality Parameter Monitoring Form

# Lead & Copper Rule Corrosion Control

County: Tillamook

Agency: Region 1

**ENTRY POINT**

**EP- A**

Day	pH	Alk	Phos	Sili	Y/N
1	8.02				Y
2	7.62				Y
3	7.98				Y
4	7.88	28			Y
5	7.78				Y
6	7.70				Y
7	7.71				Y
8	7.73				Y
9	7.75				Y
10	8.18				Y
11	8.46	27			Y
12	7.84				Y
13	8.13				Y
14	7.93				Y
15	8.18				Y
16	8.03				Y
17	7.88				Y
18	8.11	22			Y
19	7.81				Y
20	7.83				Y
21	8.22				Y
22	7.77				Y
23	7.79				Y
24	8.50	21			Y
25	7.58				Y
26	7.68				Y
27	7.72				Y
28	7.70				Y
29	7.66				Y
30	7.66				Y
31	8.15	22			Y

<< Have minimums been met for this day?

PWS ID: 41

**System Name:** Tillamook Water Dept, City of

**Sample Period:** March 2025  
Month/Year

**Number of excursions\* during this month:** 0  
( Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are Cumulative). An 'excursion' is any day in which the water quality parameter(s) fall below the minimum set by the State

**Minimum Water Quality Parameters as set by State:**

pH   
Alk  (Alkalinity)

**Print Name:** Levi Beachy  
**Signature:**   
**Date:** April 1, 2025

=N=Excursion) **Total N's**

Send to DHS within 10 days after end of sampling period

OHA Drinking Water Program, PO Box 14350, Portland, OR 97293-0350

Phone (971) 673-0405 Website: <http://healthoregon.org/dwp/>