Water Quality Parameter Monitoring Form

Lead & Copper Rule Corrosion Control

County: Tillamook Agency: Region 1

ENTRY POINT

EP- A

Day	pH	Alk	Phos	Sili	Y/N
1	7.77				Y
2	7.91				Y
3	7.79				Y
4	7.97				Y
5	8.11				Y
6	7.91				Y
7	7.73				Y
8	7.39	23			Y
9	7.69				Y
10					OFF
11					OFF
12					OFF
13					OFF
14					OFF
15		50			OFF
16	8.13				Y
17	7.72				Y
18					OFF
19					OFF
20					OFF
21	7.56	26			Y
22	7.78				Y
23	7.74				Y
24	7.77				Y
25					OFF
26					OFF
27					OFF
28	7.67	26			Y
29	7.72				Y
30	8.02				Y
31					
=N=Excursion) **Total N's**					0

<< Have minimums been met for this day?

PWS ID: 41 0 0 8 9 3

System Name: Tillamook Water Dept, City of

Sample Period April 2025

Month/Year

Number of excursions* during this month: 0

(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are Cumulative). An 'excursion' is any day in which the water quality parameter(s) fall below the minimum *set by the State*

Minimum Water Quality Parameters as set by State:

pH 7.2

Alk 20 *(Alkalinity)*

Print Name: Levi Beachy

Signature:

Date: May 5, 2025

Send to DHS within 10 days after end of sampling period

OHA Drinking Water Program, PO Box 14350, Portland, OR 97293-0350

Phone (971) 673-0405 Website: http://healthoregon.org/dwp/