



Water Quality Parameter Monitoring Form

Lead & Copper Rule Corrosion Control

County: Tillamook

Agency: Region 1

ENTRY POINT

EP- A

Day	pH	Alk	Phos	Sili	Y/N	<< Have minimums been met for this day?	PWS ID: 41	<input type="text" value="0"/> <input type="text" value="0"/> <input type="text" value="8"/> <input type="text" value="9"/> <input type="text" value="3"/>						
1	8.29				Y									
2	8.39				Y									
3	8.39				Y									
4	8.25				Y		System Name:	Tillamook Water Dept, City of						
5	8.38				Y									
6	8.10	23			Y		Sample Period	January, 2026						
7	8.29				Y			Month/Year						
8	8.38				Y									
9	8.41				Y									
10	8.36				Y		Number of excursions* during this month:	0						
11	8.27				Y		<i>(Over 9 excursions in 6 months is a violation.</i>							
12	8.38				Y		<i>Entry Point and Distribution excursions are</i>							
13	8.39				Y		<i>Cumulative). An 'excursion' is any day in which the</i>							
14	8.40				Y		<i>water quality parameter(s) fall below the minimum</i>							
15	8.09	27			Y		<i>set by the State</i>							
16	8.34				Y									
17	8.38				Y									
18	8.24				Y									
19	8.37				Y									
20	8.38				Y									
21	8.08	32			Y		Minimum Water Quality Parameters as set by State:							
22	8.41				Y									
23	8.36				Y									
24	8.41				Y			pH	<input type="text" value="7.2"/>					
25					OFF			Alk	<input type="text" value="20"/>	(Alkalinity)				
26					OFF									
27	8.06	40			Y									
28	8.34				Y									
29	8.34				Y									
30	8.50				Y		Print Name;	Levi Beachy						
31	8.51				Y		Signature:							
=N=Excursion) Total N's					<input type="text" value="0"/>		Date:	February 9, 2026						

Send to DHS within 10 days after end of sampling period

OHA Drinking Water Program, PO Box 14350, Portland, OR 97293-0350

Phone (971) 673-0405 Website: <http://healthoregon.org/dwp/>