



Water Quality Parameter Monitoring Form

Lead & Copper Rule Corrosion Control

County: Tillamook

Agency: Region 1

ENTRY POINT

EP- C

Day	pH	Alk	Phos	Sili	Y/N	<< Have minimums been met for this day?	
1	OFF				Y		
2	OFF				Y		
3	OFF				Y		
4	OFF				Y		
5	OFF				Y		
6	OFF				Y		
7	OFF				Y		
8	OFF	74			Y		
9	OFF				Y		
10	OFF				Y		
11	OFF				Y		
12	OFF				Y		
13	OFF				Y		
14	OFF	40			Y		
15	OFF				Y		
16	OFF				Y		
17	OFF				Y		
18	OFF				Y		
19	OFF	40			Y		
20	OFF				Y		
21	OFF				Y		
22	OFF				Y		
23	OFF				Y		
24	OFF				Y		
25	OFF				Y		
26	OFF				Y		
27	OFF	35			Y		
28	OFF				Y		
29	OFF				Y		
30	OFF				Y		
31	OFF				Y		
=N=Excursion) Total N's						0	

System Name: Tillamook Water Dept, City of

Sample Period: July 2021
Month/Year

Number of excursions* during this month: 0
(Over 9 excursions in 6 months is a violation.
Entry Point and Distribution excursions are
Cumulative). An 'excursion' is any day in which the
water quality parameter(s) fall below the minimum
set by the State

**Minimum Water Quality
Parameters as set by State:**

pH	7.2	
Alk	30.0	(Alkalinity)

Print Name: Levi Beachy

Signature:

Date: August 5, 2021

Send to DHS within 10 days after end of sampling period

OHA Drinking Water Program, PO Box 14350, Portland, OR 97293-0350

Phone (971) 673-0405 Website: <http://healthoregon.org/dwp/>