



Water Quality Parameter Monitoring Form

Lead & Copper Rule Corrosion Control

County: Tillamook

Agency: Region 1

ENTRY POINT

EP- C

Day	pH	Alk	Phos	Sili	Y/N	<< Have minimums been met for this day?	PWS ID: 41	0	0	8	9	3
1	OFF				Y							
2	OFF				Y							
3	OFF				Y							
4	OFF	50			Y		System Name:	Tillamook Water Dept, City of				
5	OFF				Y		Sample Period	October 2021				
6	OFF				Y			Month/Year				
7	OFF				Y							
8	OFF				Y							
9	OFF				Y							
10	OFF				Y		Number of excursions* during this month:	0				
11	OFF	49			Y		(Over 9 excursions in 6 months is a violation.					
12	OFF				Y		Entry Point and Distribution excursions are					
13	OFF				Y		Cumulative). An 'excursion' is any day in which the					
14	OFF				Y		water quality parameter(s) fall below the minimum					
15	OFF				Y		set by the State					
16	OFF				Y							
17	OFF				Y							
18	OFF	51			Y							
19	OFF				Y							
20	OFF				Y							
21	OFF				Y							
22	OFF				Y							
23	OFF				Y							
24	OFF				Y							
25	OFF	59			Y							
26	OFF				Y							
27	OFF				Y							
28	OFF				Y							
29	OFF				Y							
30	7.30				Y		Print Name:	Levi Beachy				
31	OFF				Y		Signature:					
=N=Excursion) Total N's						0	Date:	November 1, 2021				

Minimum Water Quality

Parameters as set by State:

pH 7.2
Alk 30.0 (Alkalinity)

Send to DHS within 10 days after end of sampling period

OHA Drinking Water Program, PO Box 14350, Portland, OR 97293-0350

Phone (971) 673-0405 Website: <http://healthoregon.org/dwp/>