



Water Quality Parameter Monitoring Form

Lead & Copper Rule Corrosion Control

County: Tillamook

Agency: Region 1

ENTRY POINT

EP- C

Day	pH	Alk	Phos	Sili	Y/N	<< Have
1	OFF				Y	minimums
2	OFF				Y	been met
3	OFF				Y	for this day?
4	OFF				Y	
5	OFF				Y	
6	OFF	45			Y	
7	OFF				Y	
8	OFF				Y	
9	OFF				Y	
10	OFF				Y	
11	OFF				Y	
12	OFF				Y	
13	OFF	23			Y	
14	OFF				Y	
15	OFF				Y	
16	OFF				Y	
17	OFF				Y	
18	OFF				Y	
19	OFF				Y	
20	OFF	26			Y	
21	OFF				Y	
22	OFF				Y	
23	OFF				Y	
24	OFF				Y	
25	OFF				Y	
26	OFF				Y	
27	OFF	29			Y	
28	OFF				Y	
29	OFF				Y	
30	OFF				Y	
31	OFF				Y	
=N=Excursion) Total N's						0

System Name: Tillamook Water Dept, City of

Sample Period: December 2021
Month/Year

Number of excursions* during this month: 0
(Over 9 excursions in 6 months is a violation.
Entry Point and Distribution excursions are
Cumulative). An 'excursion' is any day in which the
water quality parameter(s) fall below the minimum
set by the State

**Minimum Water Quality
Parameters as set by State:**

pH	7.2
Alk	30.0 (Alkalinity)

Print Name: Levi Beachy
Signature:
Date: January 3, 2022

Send to DHS within 10 days after end of sampling period

OHA Drinking Water Program, PO Box 14350, Portland, OR 97293-0350

Phone (971) 673-0405 Website: <http://healthoregon.org/dwp/>