


Lead & Copper Rule Corrosion Control

County: Tillamook

Agency: Region 1

ENTRY POINT

EP- C

Day	pH	Alk	Phos	Sili	Y/N	<< Have minimums been met for this day?		PWS ID: 41	0	0	8	9	3
1	7.80				OFF								
2	7.84	27			OFF								
3	7.86				OFF								
4	7.89				OFF								
5	7.60				OFF								
6	7.70				OFF								
7	7.59	44			OFF								
8	7.71				OFF								
9	7.27				OFF								
10	7.52				OFF								
11	7.56				OFF								
12	7.77				OFF								
13	7.83				OFF								
14	7.87				OFF								
15	7.90				OFF								
16	7.93	26			OFF								
17	7.93				OFF								
18	7.95				OFF								
19	7.97				OFF								
20	8.00				OFF								
21	8.02				OFF								
22	8.02	22			OFF								
23	8.04				OFF								
24	80.33				OFF								
25	7.67				OFF								
26	7.63				OFF								
27	7.65				OFF								
28	7.63				OFF								
29					OFF								
30					OFF								
31					OFF								
=N=Excursion) Total N's						0							

System Name: Tillamook Water Dept, City of


Sample Period: February 2022
Month/Year

Number of excursions* during this month: 0
(Over 9 excursions in 6 months is a violation.
Entry Point and Distribution excursions are
Cumulative). An 'excursion' is any day in which the
water quality parameter(s) fall below the minimum
set by the State

**Minimum Water Quality
Parameters as set by State:**

pH 7.2
Alk 30.0 (Alkalinity)

Print Name: Levi Beachy

Signature: 

Date: March 9, 2022

Send to DHS within 10 days after end of sampling period

OHA Drinking Water Program, PO Box 14350, Portland, OR 97293-0350

Phone (971) 673-0405 Website: <http://healthoregon.org/dwp/>