



Water Quality Parameter Monitoring Form

Lead & Copper Rule Corrosion Control

County: Tillamook

Agency: Region 1

ENTRY POINT

EP- C

Day	pH	Alk	Phos	Sili	Y/N	<< Have minimums been met for this day?	PWS ID: 41	0	0	8	9	3	
1	7.72	73			Y								
2	7.62	69			Y								
3	7.78	70			Y								
4	7.79	71			Y		System Name:	Tillamook Water Dept, City of					
5	7.80	69			Y								
6	7.66	73			Y		Sample Period	November 2022					
7	7.72	75			Y			Month/Year					
8	7.74	73			Y								
9	7.73	75			Y								
10	7.78	68			Y		Number of excursions* during this month:	0					
11	7.86	73			Y		(Over 9 excursions in 6 months is a violation.						
12	7.79	68			Y		Entry Point and Distribution excursions are						
13	7.77	69			Y		Cumulative). An 'excursion' is any day in which the						
14	7.81	80			Y		water quality parameter(s) fall below the minimum						
15					OFF		set by the State						
16					OFF								
17					OFF								
18					OFF								
19					OFF								
20					OFF								
21					OFF								
22					OFF								
23					OFF								
24					OFF								
25					OFF								
26					OFF								
27					OFF								
28	7.96	80			Y								
29	7.79	69			Y								
30	7.62	72			Y								
31													
=N=Excursion) Total N's						0							
							Print Name:	Levi Beachy					
							Signature:						
							Date:	December 6, 2022					

Minimum Water Quality
Parameters as set by State:pH 7.2
Alk 30.0 (Alkalinity)

Send to DHS within 10 days after end of sampling period

OHA Drinking Water Program, PO Box 14350, Portland, OR 97293-0350

Phone (971) 673-0405 Website: <http://healthoregon.org/dwp/>