



Water Quality Parameter Monitoring Form

Lead & Copper Rule Corrosion Control

County: Tillamook

Agency: Region 1

ENTRY POINT

EP- C

Day	pH	Alk	Phos	Sili	Y/N	<< Have minimums been met for this day?	PWS ID: 41	0 0 8 9 3						
1					Y									
2					OFF									
3					OFF									
4					OFF		System Name:	Tillamook Water Dept, City of						
5					OFF									
6					OFF		Sample Period	May 2024						
7	7.74	66			Y									
8					OFF									
9					OFF									
10					OFF		Number of excursions* during this month:	0						
11					OFF		<i>(Over 9 excursions in 6 months is a violation.</i>							
12					OFF		<i>Entry Point and Distribution excursions are</i>							
13					OFF		<i>Cumulative). An 'excursion' is any day in which the</i>							
14	8.06	61			Y		<i>water quality parameter(s) fall below the minimum</i>							
15					OFF		<i>set by the State</i>							
16					OFF									
17					OFF									
18					OFF									
19					OFF									
20	7.61	58			Y									
21					OFF									
22					OFF									
23					OFF									
24	Pump	Repair	No	Sample	OFF									
25					OFF									
26					OFF									
27					OFF									
28					OFF									
29					OFF									
30					OFF		Print Name:	Levi Beachy						
31					OFF		Signature:							
=N=Excursion) Total N's						0	Date:	June 5, 2024						

System Name: Tillamook Water Dept, City of

Sample Period May 2024
Month/Year

Number of excursions* during this month: 0
(Over 9 excursions in 6 months is a violation.
Entry Point and Distribution excursions are
Cumulative). An 'excursion' is any day in which the
water quality parameter(s) fall below the minimum
set by the State

Minimum Water Quality Parameters as set by State:	
pH	7.2
Alk	30.0 (Alkalinity)

Send to DHS within 10 days after end of sampling period
 OHA Drinking Water Program, PO Box 14350, Portland, OR 97293-0350
 Phone (971) 673-0405 Website: <http://healthoregon.org/dwp/>