



Water Quality Parameter Monitoring Form
Lead & Copper Rule Corrosion Control

County: Tillamook

Agency: Region 1

ENTRY POINT

EP- C

Day	pH	Alk	Phos	Sili	Y/N
1					OFF
2					OFF
3	7.84	45			Y
4					OFF
5					OFF
6					OFF
7					OFF
8					OFF
9					OFF
10					OFF
11					OFF
12					OFF
13					OFF
14					OFF
15					OFF
16	7.43	45			Y
17					OFF
18					OFF
19					OFF
20					OFF
21					OFF
22					OFF
23					OFF
24					OFF
25	Pump	Pulled	For	Repair	OFF
26					OFF
27					OFF
28					OFF
29					OFF
30					OFF
31					OFF

<< Have minimums been met for this day?

PWS ID: 41

System Name: Tillamook Water Dept, City of

Sample Period: June 2024
 Month/Year

Number of excursions* during this month: 0
 (Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are Cumulative). An 'excursion' is any day in which the water quality parameter(s) fall below the minimum set by the State

Minimum Water Quality Parameters as set by State:

pH
 Alk (Alkalinity)

Print Name: Levi Beachy

Signature:

Date: July 1, 2024

=N=Excursion) **Total N's**

Send to DHS within 10 days after end of sampling period

OHA Drinking Water Program, PO Box 14350, Portland, OR 97293-0350

Phone (971) 673-0405 Website: <http://healthoregon.org/dwp/>