



Water Quality Parameter Monitoring Form

Lead & Copper Rule Corrosion Control

County: Tillamook

Agency: Region 1

ENTRY POINT

EP- C

Day	pH	Alk	Phos	Sili	Y/N	<< Have
1					OFF	minimums
2					OFF	been met
3					OFF	for this day?
4					OFF	
5					OFF	
6					OFF	
7					OFF	
8					OFF	
9					OFF	
10					OFF	
11					OFF	
12					OFF	
13					OFF	
14					OFF	
15	7.32	73			Y	
16					OFF	
17					OFF	
18					OFF	
19					OFF	
20					OFF	
21					OFF	
22					OFF	
23	7.28	71			Y	
24					OFF	
25					OFF	
26					OFF	
27					OFF	
28					OFF	
29	7.27	71			Y	
30					OFF	
31					OFF	
=N=Excursion) Total N's					0	

PWS ID: 41

System Name: Tillamook Water Dept, City of

Sample Period July 2024
Month/Year

Number of excursions* during this month: 0
(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are Cumulative). An 'excursion' is any day in which the water quality parameter(s) fall below the minimum set by the State

Minimum Water Quality Parameters as set by State:

pH
Alk (Alkalinity)

Print Name: Levi Beachy

Signature:

Date: August 1, 2024

Send to DHS within 10 days after end of sampling period

OHA Drinking Water Program, PO Box 14350, Portland, OR 97293-0350

Phone (971) 673-0405 Website: <http://healthoregon.org/dwp/>