



Water Quality Parameter Monitoring Form

Lead & Copper Rule Corrosion Control

County: Tillamook

Agency: Region 1

ENTRY POINT

EP- C

Day	pH	Alk	Phos	Sili	Y/N	<< Have minimums been met for this day?	PWS ID: 41	0 0 8 9 3				
1					OFF							
2					OFF							
3					OFF							
4					OFF		System Name:	Tillamook Water Dept, City of				
5					OFF							
6					OFF		Sample Period	August 2024				
7	7.36	75			Y			Month/Year				
8					OFF							
9					OFF							
10					OFF		Number of excursions* during this month:	0				
11					OFF		<i>(Over 9 excursions in 6 months is a violation.</i>					
12					OFF		<i>Entry Point and Distribution excursions are</i>					
13					OFF		<i>Cumulative). An 'excursion' is any day in which the</i>					
14					OFF		<i>water quality parameter(s) fall below the minimum</i>					
15	7.49	67			Y		<i>set by the State</i>					
16					OFF							
17					OFF							
18					OFF							
19	7.34	68			Y							
20					OFF							
21					OFF							
22					OFF							
23					OFF							
24					OFF							
25	7.47	71			Y							
26					OFF							
27					OFF							
28					OFF							
29					OFF							
30					OFF		Print Name:	Levi Beachy				
31					OFF		Signature:					
=N=Excursion) Total N's						0	Date:	September 3, 2024				

Minimum Water Quality Parameters as set by State:

pH 7.2
Alk 30.0 (Alkalinity)

Send to DHS within 10 days after end of sampling period

OHA Drinking Water Program, PO Box 14350, Portland, OR 97293-0350

Phone (971) 673-0405 Website: <http://healthoregon.org/dwp/>