



Water Quality Parameter Monitoring Form

Lead & Copper Rule Corrosion Control

County: Tillamook

Agency: Region 1

ENTRY POINT

EP- C

Day	pH	Alk	Phos	Sili	Y/N
1					OFF
2					OFF
3	7.27	77			Y
4					OFF
5					OFF
6					OFF
7					OFF
8					OFF
9	7.41	76			Y
10					OFF
11					OFF
12					OFF
13					OFF
14					OFF
15					OFF
16	7.36	67			Y
17					OFF
18	8.24				Y
19	8.48				Y
20					OFF
21					OFF
22					OFF
23	7.21	74			Y
24	8.15				Y
25	8.13				Y
26	8.21				Y
27	8.20				Y
28	8.12				Y
29	8.09				Y
30	7.52	67			Y
31					

<< Have minimums been met for this day?

PWS ID: 41

System Name: Tillamook Water Dept, City of

Sample Period: September 2024
Month/Year

Number of excursions* during this month: 0
(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are Cumulative). An 'excursion' is any day in which the water quality parameter(s) fall below the minimum set by the State

Minimum Water Quality Parameters as set by State:

pH	<input type="text" value="7.2"/>	
Alk	<input type="text" value="30.0"/>	(Alkalinity)

Print Name: Levi Beachy
Signature:
Date: October 8, 2024

=N=Excursion) **Total N's**

Send to DHS within 10 days after end of sampling period
OHA Drinking Water Program, PO Box 14350, Portland, OR 97293-0350
Phone (971) 673-0405 Website: <http://healthoregon.org/dwp/>