Oregon Health Authority

Water Quality Parameter Monitoring Form

Lead & Copper Rule Corrosion Control

County: Tillamook

Agency: Region 1

ENTRY POINT

EP- C

Day	pH	Alk	Phos	Sili	Y/N
1					OFF
2					OFF
3					OFF
4					OFF
5					OFF
6					OFF
7	8.07				Y
8	7.21	68			Y
9	8.15				Y
10	8.04				Y
11	8.02				Y
12	7.91				Y
13	7.78				Y
14	8.02				Y
15	7.21	62			Y
16	7.84				Y
17	8.02				Y
18	7.96				Y
19	7.93				Y
20	8.00				Y
21	7.20	51			Y
22	7.90				Y
23	8.00				Y
24	7.96				Y
25	7.76				Y
26	8.02				Y
27	7.91				Y
28	7.22	67			Y
29					OFF
30					OFF
31					
=N=Excursion) **Total N's**					0

<< Have minimums been met for this day?

PWS ID: 41 0 0 8 9 3

System Name: Tillamook Water Dept, City of

Sample Period April 2025

Month/Year

Number of excursions* during this month: 0

(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are Cumulative). An 'excursion' is any day in which the water quality parameter(s) fall below the minimum *set by the State*

Minimum Water Quality Parameters as set by State:

pH 7.2

Alk 30.0 *(Alkalinity)*

Print Name: AJ Harmon

Signature:

Date: May 5, 2025

Send to DHS within 10 days after end of sampling period

OHA Drinking Water Program, PO Box 14350, Portland, OR 97293-0350

Phone (971) 673-0405 Website: http://healthoregon.org/dwp/

pg. 1