



Water Quality Parameter Monitoring Form  
**Lead & Copper Rule Corrosion Control**

County: Tillamook

Agency: Region 1

**ENTRY POINT**

**EP- C**

Day	pH	Alk	Phos	Sili	Y/N	<< Have minimums been met for this day?	PWS ID: 41	0	0	8	9	3	
1					OFF								
2					OFF	been met							
3					OFF	for this day?							
4					OFF		System Name:	Tillamook Water Dept, City of					
5					OFF								
6					OFF		Sample Period	October, 2025					
7	8.53	79			Y			Month/Year					
8					OFF								
9					OFF								
10					OFF		Number of excursions* during this month:	0					
11					OFF		( Over 9 excursions in 6 months is a violation.						
12					OFF		Entry Point and Distribution excursions are						
13	8.45	83			Y		Cumulative). An 'excursion' is any day in which the						
14					OFF		water quality parameter(s) fall below the minimum						
15					OFF		set by the State						
16					OFF								
17					OFF								
18					OFF								
19					OFF								
20	8.62	83			Y		Minimum Water Quality						
21					OFF		Parameters as set by State:						
22					OFF								
23					OFF								
24	8.19				Y		pH	7.2					
25					OFF		Alk	30.0	(Alkalinity)				
26	8.21				Y								
27	8.56	70			Y								
28					OFF								
29					OFF								
30					OFF		Print Name:	Austin Harmon					
31					OFF		Signature:						
(N=Excursion) Total N's						0	Date:	November 3, 2025					

Send to DHS within 10 days after end of sampling period

OHA Drinking Water Program, PO Box 14350, Portland, OR 97293-0350

Phone (971) 673-0405 Website: <http://healthoregon.org/dwp/>