



Water Quality Parameter Monitoring Form  
**Lead & Copper Rule Corrosion Control**

County: Tillamook

Agency: Region 1

**ENTRY POINT**

**EP- C**

Day	pH	Alk	Phos	Sili	Y/N	<< Have minimums been met for this day?	PWS ID: 41	0	0	8	9	3
1					OFF							
2	8.35				Y	been met						
3					OFF	for this day?						
4	8.61	71			Y		System Name:	Tillamook Water Dept, City of				
5					OFF							
6					OFF		Sample Period	November, 2025				
7					OFF			Month/Year				
8	8.34				Y							
9					OFF							
10					OFF		Number of excursions* during this month:	0				
11					OFF		( Over 9 excursions in 6 months is a violation.					
12	8.49				Y		Entry Point and Distribution excursions are					
13	8.65	73			Y		Cumulative). An 'excursion' is any day in which the					
14					OFF		water quality parameter(s) fall below the minimum					
15					OFF		set by the State					
16					OFF							
17	8.63	74			Y							
18					OFF							
19					OFF							
20					OFF							
21					OFF		Minimum Water Quality					
22					OFF		Parameters as set by State:					
23					OFF							
24					OFF		pH 7.2					
25	8.59	85			Y		Alk 30.0 (Alkalinity)					
26					OFF							
27					OFF							
28					OFF							
29					OFF							
30					OFF							
(N=Excursion) Total N's						0	Print Name:	Austin Harmon				
							Signature:					
						Date:	December 1, 2025					

Send to DHS within 10 days after end of sampling period

OHA Drinking Water Program, PO Box 14350, Portland, OR 97293-0350

Phone (971) 673-0405 Website: <http://healthoregon.org/dwp/>