



Water Quality Parameter Monitoring Form

**Lead & Copper Rule Corrosion Control**

County: Tillamook

Agency: Region 1

**ENTRY POINT**

**EP- D**

Day	pH	Alk	Phos	Sili	Y/N
1	7.31				Y
2	7.22	42			Y
3	7.20				Y
4	7.20				Y
5	7.22				Y
6	7.20				Y
7	7.20				Y
8	OFF				Y
9	OFF				Y
10	OFF				Y
11	7.20	45			Y
12	7.21				Y
13	7.20				Y
14	7.21				Y
15	7.28				Y
16	7.21	43			Y
17	7.20				Y
18	7.22				Y
19	7.20				Y
20	7.20				Y
21	7.20				Y
22	7.24				Y
23	7.36				Y
24	7.31				Y
25	7.29	46			Y
26	7.31				Y
27	7.30				Y
28	7.31				Y
29	7.31				Y
30	7.32	55			Y
31	7.30				Y

<< Have minimums been met for this day?

PWS ID: 41

**System Name:** Tillamook Water Dept, City of

**Sample Period:** August 2021  
Month/Year

**Number of excursions\* during this month:** 0  
( Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are Cumulative). An 'excursion' is any day in which the water quality parameter(s) fall below the minimum set by the State

**Minimum Water Quality Parameters as set by State:**

pH	<input type="text" value="7.2"/>	
Alk	<input type="text" value="30.0"/>	(Alkalinity)
	<input type="text"/>	

**Print Name:** Levi Beachy

**Signature:**

**Date:** September 1, 2021

(N=Excursion) **Total N's**

Send to DHS within 10 days after end of sampling period

OHA Drinking Water Program, PO Box 14350, Portland, OR 97293-0350

Phone (971) 673-0405 Website: <http://healthoregon.org/dwp/>