



Water Quality Parameter Monitoring Form

Lead & Copper Rule Corrosion Control

County: Tillamook

Agency: Region 1

ENTRY POINT

EP- D

Day	pH	Alk	Phos	Sili	Y/N	<< Have minimums been met for this day?	PWS ID: 41	0	0	8	9	3
1	7.49				Y							
2	7.47				Y							
3	7.45				Y							
4	7.47	48			Y		System Name:	Tillamook Water Dept, City of				
5	7.47				Y							
6	7.35				Y		Sample Period	October 2021				
7	OFF				Y			Month/Year				
8	7.34				Y							
9	7.34				Y							
10	7.32				Y		Number of excursions* during this month:	0				
11	7.32	50			Y		(Over 9 excursions in 6 months is a violation.					
12	7.34				Y		Entry Point and Distribution excursions are					
13	OFF				Y		Cumulative). An 'excursion' is any day in which the					
14	7.34				Y		water quality parameter(s) fall below the minimum					
15	7.31				Y		set by the State					
16	OFF				Y							
17	OFF				Y							
18	7.32	50			Y							
19	OFF				Y							
20	OFF				Y							
21	OFF				Y							
22	7.31				Y		Minimum Water Quality					
23	OFF				Y		Parameters as set by State:					
24	7.34				Y		pH	7.2				
25	7.31	52			Y		Alk	30.0	(Alkalinity)			
26	7.32				Y							
27	7.30				Y							
28	7.30				Y							
29	OFF				Y							
30	7.24				Y		Print Name:	Levi Beachy				
31	7.28				Y		Signature:					
=N=Excursion) Total N's						0	Date:	November 1, 2021				

Send to DHS within 10 days after end of sampling period

OHA Drinking Water Program, PO Box 14350, Portland, OR 97293-0350

Phone (971) 673-0405 Website: <http://healthoregon.org/dwp/>