



Water Quality Parameter Monitoring Form

Lead & Copper Rule Corrosion Control

County: Tillamook

Agency: Region 1

ENTRY POINT

EP- D

Day	pH	Alk	Phos	Sili	Y/N
1	7.28	52			Y
2	7.29				Y
3	7.29				Y
4	7.24				Y
5	7.28				Y
6	7.29				Y
7	OFF				Y
8	OFF	56			Y
9	OFF				Y
10	OFF				Y
11	OFF				Y
12	7.24				Y
13	7.26				Y
14	7.25				Y
15	7.28	52			Y
16	OFF				Y
17	OFF				Y
18	OFF				Y
19	OFF				Y
20	OFF				Y
21	OFF				Y
22	OFF				Y
23	OFF	37			Y
24	OFF				Y
25	OFF				Y
26	OFF				Y
27	OFF				Y
28	OFF				Y
29	OFF				Y
30	OFF	52			Y
31					Y

<< Have
minimums
been met
for this day?

PWS ID: 41

0 0 8 9 3

System Name:

Tillamook Water Dept, City of

Sample Period

November 2021

Month/Year

Number of excursions* during this month:

0

(Over 9 excursions in 6 months is a violation.

Entry Point and Distribution excursions are

Cumulative). An 'excursion' is any day in which the

water quality parameter(s) fall below the minimum

set by the State

Minimum Water Quality

Parameters as set by State:

pH 7.2

Alk 30.0

(Alkalinity)

Print Name:

Levi Beachy

Signature:

Date: December 1, 2021

=N=Excursion) Total N's

0

Send to DHS within 10 days after end of sampling period

OHA Drinking Water Program, PO Box 14350, Portland, OR 97293-0350

Phone (971) 673-0405 Website: <http://healthoregon.org/dwp/>