



Water Quality Parameter Monitoring Form

Lead & Copper Rule Corrosion Control

County: Tillamook

Agency: Region 1

ENTRY POINT

EP- D

Day	pH	Alk	Phos	Sili	Y/N	<< Have
1	7.40				Y	minimums
2	7.53				OFF	been met
3	7.38	52			Y	for this day?
4	7.48				OFF	
5	7.44				OFF	
6	7.42				Y	
7	7.36				Y	
8	7.41				OFF	
9	7.39				OFF	
10	7.42				OFF	
11	7.42				OFF	
12	7.49	51			OFF	
13	7.45				OFF	
14	7.74				OFF	
15	7.39				OFF	
16	7.56				OFF	
17	7.39				OFF	
18	7.62				OFF	
19	7.38	51			OFF	
20	7.72				OFF	
21	7.37				OFF	
22	7.45				OFF	
23	7.43				OFF	
24	7.61				OFF	
25	7.53				OFF	
26	7.50	59			OFF	
27	7.38				OFF	
28	7.42				OFF	
29	7.46				OFF	
30	7.66				OFF	
31	7.80				OFF	

PWS ID: 41

System Name: Tillamook Water Dept, City of

Sample Period January 2022
Month/Year

Number of excursions* during this month: 0
(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are Cumulative). An 'excursion' is any day in which the water quality parameter(s) fall below the minimum set by the State

Minimum Water Quality Parameters as set by State:

pH
Alk (Alkalinity)

Print Name: Levi Beachy

Signature:

Date: February 1, 2022

=N=Excursion) **Total N's**

Send to DHS within 10 days after end of sampling period

OHA Drinking Water Program, PO Box 14350, Portland, OR 97293-0350

Phone (971) 673-0405 Website: <http://healthoregon.org/dwp/>