

## Lead & Copper Rule Corrosion Control

County: Tillamook

Agency: Region 1

ENTRY POINT

EP- D

Day	pH	Alk	Phos	Sili	Y/N	<< Have minimums been met for this day?	PWS ID: 41	0	0	8	9	3
1	7.35				Y							
2					OFF							
3					OFF							
4					OFF							
5					OFF							
6					OFF							
7					OFF							
8					OFF							
9					OFF							
10					OFF							
11					OFF							
12					OFF							
13					OFF							
14					OFF							
15					OFF							
16					OFF							
17					OFF							
18					OFF							
19					OFF							
20					OFF							
21					OFF							
22					OFF							
23					OFF							
24					OFF							
25					OFF							
26					OFF							
27					OFF							
28					OFF							
29					OFF							
30					OFF							
31					OFF							
=N=Excursion) Total N's						0						


**System Name:** Tillamook Water Dept, City of

**Sample Period** March 2022  
Month/Year

**Number of excursions\* during this month:** 0  
( Over 9 excursions in 6 months is a violation.  
Entry Point and Distribution excursions are  
Cumulative). An 'excursion' is any day in which the  
water quality parameter(s) fall below the minimum  
set by the State

**Minimum Water Quality  
Parameters as set by State:**

pH 7.2  
Alk 30.0 (Alkalinity)

**Print Name:** Levi Beachy  
**Signature:**   
**Date:** April 5, 2022

Send to DHS within 10 days after end of sampling period

OHA Drinking Water Program, PO Box 14350, Portland, OR 97293-0350

Phone (971) 673-0405 Website: <http://healthoregon.org/dwp/>