



Water Quality Parameter Monitoring Form  
**Lead & Copper Rule Corrosion Control**

County: Tillamook

Agency: Region 1

**ENTRY POINT**

**EP- D**

Day	pH	Alk	Phos	Sili	Y/N	<< Have minimums been met for this day?	PWS ID: 41	<input type="text" value="0"/> <input type="text" value="0"/> <input type="text" value="8"/> <input type="text" value="9"/> <input type="text" value="3"/>				
1					OFF							
2					OFF							
3					OFF							
4					OFF		<b>System Name:</b>	Tillamook Water Dept, City of				
5					OFF							
6					OFF		<b>Sample Period</b>	June 2022				
7					OFF			Month/Year				
8					OFF							
9					OFF							
10	7.32	53			Y		<b>Number of excursions* during this month:</b>	0				
11					OFF		<i>( Over 9 excursions in 6 months is a violation.</i>					
12					OFF		<i>Entry Point and Distribution excursions are</i>					
13					OFF		<i>Cumulative). An 'excursion' is any day in which the</i>					
14					OFF		<i>water quality parameter(s) fall below the minimum</i>					
15	7.94	49			Y		<i>set by the State</i>					
16					OFF							
17					OFF							
18					OFF							
19					OFF							
20					OFF							
21					OFF							
22					OFF							
23					OFF							
24					OFF							
25					OFF							
26	7.30	59			Y							
27	7.35	50			Y							
28					OFF							
29	7.42	47			Y							
30					OFF		<b>Print Name:</b>	Levi Beachy				
31					OFF		<b>Signature:</b>					
=N=Excursion) Total N's							<b>Date:</b>	July 5, 2022				

**Minimum Water Quality Parameters as set by State:**

pH

Alk  (Alkalinity)

Send to DHS within 10 days after end of sampling period

OHA Drinking Water Program, PO Box 14350, Portland, OR 97293-0350

Phone (971) 673-0405 Website: <http://healthoregon.org/dwp/>