



Water Quality Parameter Monitoring Form

# Lead & Copper Rule Corrosion Control

County: Tillamook

Agency: Region 1

**ENTRY POINT**

**EP- D**

Day	pH	Alk	Phos	Sili	Y/N	<< Have minimums been met for this day?
1					OFF	
2					OFF	
3	7.39				Y	
4					OFF	
5	7.31				Y	
6					OFF	
7					OFF	
8					OFF	
9					OFF	
10					OFF	
11	7.34				Y	
12					OFF	
13					OFF	
14					OFF	
15					OFF	
16					OFF	
17					OFF	
18					OFF	
19	7.33				Y	
20	7.36				Y	
21					OFF	
22					OFF	
23	7.36				Y	
24	7.31				Y	
25	7.36				Y	
26	7.31				Y	
27	7.30				Y	
28	7.33				Y	
29	7.32				Y	
30	7.43	48			Y	
31	7.33				Y	
=N=Excursion) Total N's					<b>0</b>	

PWS ID: 41

**System Name:** Tillamook Water Dept, City of

**Sample Period** August 2022  
Month/Year

**Number of excursions\* during this month:** 0  
( Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are Cumulative). An 'excursion' is any day in which the water quality parameter(s) fall below the minimum set by the State

**Minimum Water Quality Parameters as set by State:**

pH   
Alk  (Alkalinity)

**Print Name:** Levi Beachy

**Signature:**

**Date:** September 1, 2022

Send to DHS within 10 days after end of sampling period

OHA Drinking Water Program, PO Box 14350, Portland, OR 97293-0350

Phone (971) 673-0405 Website: <http://healthoregon.org/dwp/>