



Water Quality Parameter Monitoring Form

Lead & Copper Rule Corrosion Control

County: Tillamook

Agency: Region 1

ENTRY POINT

EP- D

Day	pH	Alk	Phos	Sili	Y/N	<< Have minimums been met for this day?	PWS ID: 41	0	0	8	9	3
1					OFF							
2					OFF							
3	7.50	51			Y							
4					OFF		System Name:	Tillamook Water Dept, City of				
5					OFF							
6					OFF		Sample Period	October 2022				
7					OFF			Month/Year				
8					OFF							
9					OFF							
10					OFF		Number of excursions* during this month:	0				
11					OFF		(Over 9 excursions in 6 months is a violation.					
12					OFF		Entry Point and Distribution excursions are					
13	7.57	47			Y		Cumulative). An 'excursion' is any day in which the					
14					OFF		water quality parameter(s) fall below the minimum					
15					OFF		set by the State					
16					OFF							
17	7.57	47			Y							
18					OFF							
19					OFF							
20					OFF							
21					OFF							
22					OFF							
23					OFF							
24	7.73	53			Y							
25					OFF							
26					OFF							
27					OFF							
28					OFF							
29					OFF							
30					OFF							
31	7.73	53			Y							
=N=Excursion) Total N's						0						

Minimum Water Quality Parameters as set by State:

pH 7.2

Alk 30.0 (Alkalinity)

Print Name: Levi Beachy

Signature:

Date: November 2, 2022

Send to DHS within 10 days after end of sampling period

OHA Drinking Water Program, PO Box 14350, Portland, OR 97293-0350

Phone (971) 673-0405 Website: <http://healthoregon.org/dwp/>