



Water Quality Parameter Monitoring Form

# Lead & Copper Rule Corrosion Control

County: Tillamook

Agency: Region 1

**ENTRY POINT**

**EP- D**

Day	pH	Alk	Phos	Sili	Y/N	<< Have
1	7.30				Y	minimums
2	7.30				Y	been met
3	7.33				Y	for this day?
4	7.30				Y	
5	7.28				Y	
6					OFF	
7	7.30				Y	
8	7.31				Y	
9	7.32	53			Y	
10	7.32				Y	
11					OFF	
12					OFF	
13	7.30				Y	
14	7.31	61			Y	
15	7.34				Y	
16					OFF	
17					OFF	
18	7.32				Y	
19					OFF	
20					OFF	
21	7.32	48			Y	
22	7.35				Y	
23	7.30				Y	
24					OFF	
25					OFF	
26	7.32				Y	
27					OFF	
28	7.27				Y	
29					OFF	
30					OFF	
31						

PWS ID: 41

**System Name:** Tillamook Water Dept, City of

**Sample Period** November 2022  
Month/Year

**Number of excursions\* during this month:** 0  
( Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are Cumulative). An 'excursion' is any day in which the water quality parameter(s) fall below the minimum set by the State

**Minimum Water Quality Parameters as set by State:**

pH   
Alk  (Alkalinity)

**Print Name:** Levi Beachy

**Signature:**

**Date:** December 6, 2022

=N=Excursion) Total N's

Send to DHS within 10 days after end of sampling period

OHA Drinking Water Program, PO Box 14350, Portland, OR 97293-0350

Phone (971) 673-0405 Website: <http://healthoregon.org/dwp/>