



Water Quality Parameter Monitoring Form

Lead & Copper Rule Corrosion Control

County: Tillamook

Agency: Region 1

ENTRY POINT

EP- D

Day	pH	Alk	Phos	Sili	Y/N	<< Have minimums been met for this day?		PWS ID: 41	0	0	8	9	3
1	7.28				Y								
2	7.32				Y								
3	7.27				Y								
4					OFF								
5	7.29				Y								
6	7.29				Y								
7					OFF								
8	7.27	50			Y								
9	7.30				Y								
10	7.25				Y								
11					OFF								
12	7.29				Y								
13					OFF								
14	7.30				Y								
15	7.31				Y								
16					OFF								
17					OFF								
18					OFF								
19	7.31				Y								
20					OFF								
21	7.34				Y								
22					OFF								
23	7.36				Y								
24	7.32				Y								
25	7.35				Y								
26					OFF								
27					OFF								
28	7.40				Y								
29	7.28				Y								
30	7.35				Y								
31	7.37				Y								
=N=Excursion) Total N's						0							

System Name: Tillamook Water Dept, City of

Sample Period: December 2022
Month/Year

Number of excursions* during this month: 0
(Over 9 excursions in 6 months is a violation.
Entry Point and Distribution excursions are
Cumulative). An 'excursion' is any day in which the
water quality parameter(s) fall below the minimum
set by the State

**Minimum Water Quality
Parameters as set by State:**

pH	7.2	(Alkalinity)
Alk	30.0	

Print Name: Levi Beachy
Signature: 
Date: January 3, 2023

Send to DHS within 10 days after end of sampling period

OHA Drinking Water Program, PO Box 14350, Portland, OR 97293-0350

Phone (971) 673-0405 Website: <http://healthoregon.org/dwp/>