



Water Quality Parameter Monitoring Form
Lead & Copper Rule Corrosion Control

County: Tillamook

Agency: Region 1

ENTRY POINT

EP- D

Day	pH	Alk	Phos	Sili	Y/N	<< Have minimums been met for this day?	PWS ID: 41									
1					OFF		0	0	8	9	3					
2					OFF		System Name: Tillamook Water Dept, City of									
3					OFF											
4					OFF		Sample Period February 2023 Month/Year									
5					OFF											
6	7.24	53			Y		<p>Number of excursions* during this month: 0 <i>(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are Cumulative). An 'excursion' is any day in which the water quality parameter(s) fall below the minimum set by the State</i></p> <div style="border: 1px solid black; padding: 5px; margin-top: 10px;"> <p style="text-align: center;">Minimum Water Quality Parameters as set by State:</p> <table style="margin-left: auto; margin-right: auto;"> <tr> <td style="padding-right: 10px;">pH</td> <td style="border: 1px solid black; padding: 2px 5px;">7.2</td> <td rowspan="2" style="padding-left: 10px;">(Alkalinity)</td> </tr> <tr> <td>Alk</td> <td style="border: 1px solid black; padding: 2px 5px;">30.0</td> </tr> </table> </div>					pH	7.2	(Alkalinity)	Alk	30.0
pH	7.2	(Alkalinity)														
Alk	30.0															
7					OFF											
8					OFF											
9					OFF											
10					OFF											
11					OFF											
12					OFF											
13	7.36	49			Y											
14					OFF											
15					OFF											
16					OFF											
17					OFF											
18					OFF											
19					OFF											
20					OFF											
21	7.34				Y											
22					OFF											
23	7.34				Y											
24					OFF											
25	7.30				Y											
26					OFF											
27	7.34				Y											
28					OFF											
29																
30																
31																
=N=Excursion) Total N's					0	Print Name: Levi Beachy		Signature:								
						Date: March 8, 2023										

Send to DHS within 10 days after end of sampling period

OHA Drinking Water Program, PO Box 14350, Portland, OR 97293-0350

Phone (971) 673-0405 Website: <http://healthoregon.org/dwp/>