



Water Quality Parameter Monitoring Form

Lead & Copper Rule Corrosion Control

County: Tillamook

Agency: Region 1

ENTRY POINT

EP- D

Day	pH	Alk	Phos	Sili	Y/N	<< Have
1	7.23	48			Y	minimums
2					OFF	been met
3					OFF	for this day?
4					OFF	
5	7.37				Y	
6					OFF	
7	7.45				Y	
8	7.38	47			Y	
9	7.36				Y	
10					OFF	
11	7.44				Y	
12					OFF	
13					OFF	
14					OFF	
15					OFF	
16					OFF	
17					OFF	
18					OFF	
19					OFF	
20					OFF	
21					OFF	
22	7.48	49			Y	
23					OFF	
24	7.32				Y	
25	7.31				Y	
26					OFF	
27					OFF	
28					OFF	
29					OFF	
30	7.49	53			Y	
31					OFF	

<< Have
minimums
been met
for this day?

PWS ID: 41

0 0 8 9 3

System Name:

Tillamook Water Dept, City of

Sample Period

May 2023

Month/Year

Number of excursions* during this month:

0

(Over 9 excursions in 6 months is a violation.

Entry Point and Distribution excursions are

Cumulative). An 'excursion' is any day in which the

water quality parameter(s) fall below the minimum
set by the State

Minimum Water Quality

Parameters as set by State:

pH 7.2

Alk 30.0

(Alkalinity)

Print Name:

Levi Beachy

Signature:

Date:

June 1, 2023

=N=Excursion) Total N's

0

Send to DHS within 10 days after end of sampling period

OHA Drinking Water Program, PO Box 14350, Portland, OR 97293-0350

Phone (971) 673-0405 Website: <http://healthoregon.org/dwp/>