



Water Quality Parameter Monitoring Form  
**Lead & Copper Rule Corrosion Control**

County: Tillamook

Agency: Region 1

**ENTRY POINT**

**EP- D**

Day	pH	Alk	Phos	Sili	Y/N	<< Have
1	7.68	48			Y	minimums
2					OFF	been met
3					OFF	for this day?
4	8.54	no	sample		Y	
5					OFF	
6					OFF	
7					OFF	
8	8.54	51			Y	
9					OFF	
10					OFF	
11					OFF	
12					OFF	
13					OFF	
14					OFF	
15	9.29	51			Y	
16					OFF	
17					OFF	
18					OFF	
19					OFF	
20					OFF	
21					OFF	
22	8.59	51			Y	
23					OFF	
24					OFF	
25					OFF	
26					OFF	
27					OFF	
28					OFF	
29					OFF	
30	8.54	51			Y	
31						

PWS ID: 41

**System Name:** Tillamook Water Dept, City of


**Sample Period:** April 2024  
 Month/Year

**Number of excursions\* during this month:** 0  
 ( Over 9 excursions in 6 months is a violation.  
 Entry Point and Distribution excursions are  
 Cumulative). An 'excursion' is any day in which the  
 water quality parameter(s) fall below the minimum  
 set by the State

**Minimum Water Quality  
 Parameters as set by State:**

pH

Alk  (Alkalinity)

**Print Name:** Levi Beachy  
**Signature:**   
**Date:** May 1, 2024

=N=Excursion) **Total N's**

Send to DHS within 10 days after end of sampling period

OHA Drinking Water Program, PO Box 14350, Portland, OR 97293-0350

Phone (971) 673-0405 Website: <http://healthoregon.org/dwp/>