



Water Quality Parameter Monitoring Form  
**Lead & Copper Rule Corrosion Control**

County: Tillamook

Agency: Region 1

**ENTRY POINT**

**EP- D**

Day	pH	Alk	Phos	Sili	Y/N	<< Have minimums been met for this day?	PWS ID: 41	<input type="text" value="0"/> <input type="text" value="0"/> <input type="text" value="8"/> <input type="text" value="9"/> <input type="text" value="3"/>					
1					OFF								
2					OFF								
3	7.21	46			Y								
4					OFF		<b>System Name:</b>	Tillamook Water Dept, City of					
5					OFF								
6					OFF		<b>Sample Period</b>	July 2024					
7					OFF			Month/Year					
8	7.61	42			Y								
9					OFF								
10					OFF		<b>Number of excursions* during this month:</b>	0					
11					OFF		<i>( Over 9 excursions in 6 months is a violation.</i>						
12					OFF		<i>Entry Point and Distribution excursions are</i>						
13					OFF		<i>Cumulative). An 'excursion' is any day in which the</i>						
14					OFF		<i>water quality parameter(s) fall below the minimum</i>						
15	7.36	52			Y		<i>set by the State</i>						
16					OFF								
17					OFF								
18					OFF								
19					OFF								
20					OFF								
21					OFF								
22					OFF								
23	7.37	49			Y								
24					OFF								
25					OFF								
26					OFF								
27					OFF								
28					OFF								
29	7.29	51			Y								
30					OFF		<b>Print Name:</b>	Levi Beachy					
31					OFF		<b>Signature:</b>						
=N=Excursion) Total N's					<b>0</b>		<b>Date:</b>	August 1, 2024					

**System Name:** Tillamook Water Dept, City of

**Sample Period** July 2024  
Month/Year

**Number of excursions\* during this month:** 0  
*( Over 9 excursions in 6 months is a violation.*  
*Entry Point and Distribution excursions are*  
*Cumulative). An 'excursion' is any day in which the*  
*water quality parameter(s) fall below the minimum*  
*set by the State*

<b>Minimum Water Quality Parameters as set by State:</b>		
pH	<input type="text" value="7.2"/>	
Alk	<input type="text" value="30.0"/>	(Alkalinity)
	<input type="text"/>	

Send to DHS within 10 days after end of sampling period

OHA Drinking Water Program, PO Box 14350, Portland, OR 97293-0350

Phone (971) 673-0405 Website: <http://healthoregon.org/dwp/>