



Water Quality Parameter Monitoring Form

# Lead & Copper Rule Corrosion Control

County: Tillamook

Agency: Region 1

## ENTRY POINT

### EP- D

Day	pH	Alk	Phos	Sili	Y/N	<< Have minimums been met for this day?	PWS ID: 41	0 0 8 9 3				
1					OFF							
2					OFF							
3					OFF							
4					OFF		<b>System Name:</b>	Tillamook Water Dept, City of				
5	8.44				Y		<b>Sample Period</b>	August 2024				
6					OFF			Month/Year				
7	7.53	46			Y							
8					OFF							
9					OFF							
10					OFF		<b>Number of excursions* during this month:</b>	0				
11					OFF		<i>( Over 9 excursions in 6 months is a violation.</i>					
12					OFF		<i>Entry Point and Distribution excursions are</i>					
13					OFF		<i>Cumulative). An 'excursion' is any day in which the</i>					
14	8.59				Y		<i>water quality parameter(s) fall below the minimum</i>					
15	7.43	41			Y		<i>set by the State</i>					
16					OFF							
17					OFF							
18					OFF							
19	7.50	41			Y							
20					OFF							
21					OFF							
22					OFF							
23					OFF							
24	8.59				Y							
25	7.47	49			Y							
26	8.63				Y							
27					OFF							
28	8.78				Y							
29	8.52				Y							
30	8.56				Y							
31	8.50				Y							
=N=Excursion) Total N's					0							

System Name: Tillamook Water Dept, City of

Sample Period: August 2024  
Month/Year

Number of excursions\* during this month: 0  
( Over 9 excursions in 6 months is a violation.  
Entry Point and Distribution excursions are  
Cumulative). An 'excursion' is any day in which the  
water quality parameter(s) fall below the minimum  
set by the State

**Minimum Water Quality Parameters as set by State:**

pH

Alk  (Alkalinity)

**Print Name:** Levi Beachy  
**Signature:**   
**Date:** September 3, 2024

Send to DHS within 10 days after end of sampling period  
OHA Drinking Water Program, PO Box 14350, Portland, OR 97293-0350  
Phone (971) 673-0405 Website: <http://healthoregon.org/dwp/>