



Water Quality Parameter Monitoring Form

**Lead & Copper Rule Corrosion Control**

County: Tillamook

Agency: Region 1

**ENTRY POINT**

**EP- D**

Day	pH	Alk	Phos	Sili	Y/N
1	7.73				Y
2	7.70				Y
3	7.69				Y
4	7.46	47			Y
5	7.68				Y
6	7.75				Y
7	7.81				Y
8	7.75				Y
9	7.72				Y
10	7.70				Y
11	7.76				Y
12	7.36	47			Y
13	7.70				Y
14	7.72				Y
15	7.75				Y
16	7.86				Y
17	7.62				Y
18	7.82				Y
19	7.49	44			Y
20	7.78				Y
21	7.76				Y
22	7.75				Y
23	7.72				Y
24	7.71				Y
25	7.44	47			Y
26	7.85				Y
27	7.85				Y
28	7.85				Y
29	7.86				Y
30	7.81				Y
31					

<< Have  
minimums  
been met  
for this day?

PWS ID: 41

**System Name:** Tillamook Water Dept, City of


**Sample Period** November 2024  
Month/Year

**Number of excursions\* during this month:** 0  
( Over 9 excursions in 6 months is a violation.  
Entry Point and Distribution excursions are  
Cumulative). An 'excursion' is any day in which the  
water quality parameter(s) fall below the minimum  
set by the State

**Minimum Water Quality  
Parameters as set by State:**

pH

Alk  (Alkalinity)

**Print Name:** Levi Beachy  
**Signature:**   
**Date:** December 5, 2024

=N=Excursion) **Total N's**

Send to DHS within 10 days after end of sampling period  
OHA Drinking Water Program, PO Box 14350, Portland, OR 97293-0350  
Phone (971) 673-0405 Website: <http://healthoregon.org/dwp/>