



Water Quality Parameter Monitoring Form

Lead & Copper Rule Corrosion Control

County: Tillamook

Agency: Region 1

ENTRY POINT

EP- D

Day	pH	Alk	Phos	Sili	Y/N	<< Have
1	8.03				Y	minimums
2					OFF	been met
3	7.84				Y	for this day?
4	7.83				Y	
5	7.85				Y	
6					OFF	
7	7.31	47			Y	
8					OFF	
9					OFF	
10					OFF	
11	7.85				Y	
12	7.86				Y	
13	7.45	45			Y	
14	7.92				Y	
15	7.98				Y	
16					OFF	
17	7.93				Y	
18	7.99				Y	
19	7.94				Y	
20	7.93				Y	
21	7.61	50			Y	
22	7.79				Y	
23					OFF	
24					OFF	
25					OFF	
26					OFF	
27	7.68	48			Y	
28					OFF	
29					OFF	
30	7.60				Y	
31	7.57				Y	
=N=Excursion) Total N's						0

PWS ID: 41

System Name:

Tillamook Water Dept, City of

Sample Period

January 2025

Month/Year

Number of excursions* during this month:

0

(Over 9 excursions in 6 months is a violation.

Entry Point and Distribution excursions are

Cumulative). An 'excursion' is any day in which the

water quality parameter(s) fall below the minimum set by the State

Minimum Water Quality

Parameters as set by State:

pH

Alk

(Alkalinity)

Print Name:

AJ Harmon

Signature:

Date:

February 3, 2025

Send to DHS within 10 days after end of sampling period

OHA Drinking Water Program, PO Box 14350, Portland, OR 97293-0350

Phone (971) 673-0405 Website: <http://healthoregon.org/dwp/>