



## Water Quality Parameter Monitoring Form

## Lead &amp; Copper Rule Corrosion Control

County: Tillamook

Agency: Region 1

ENTRY POINT

EP- D

Day	pH	Alk	Phos	Sili	Y/N	<< Have	
1					OFF	minimums	
2					OFF	been met	PWS ID: 41
3					OFF	for this day?	0 0 8 9 3
4	8.04				Y		System Name: Tillamook Water Dept, City of
5	8.08				Y		
6	8.10				Y		Sample Period May 2025
7	8.07	50			Y		Month/Year
8					OFF		
9	8.05				Y		
10	8.14				Y		Number of excursions* during this month: 0
11	8.12				Y		( Over 9 excursions in 6 months is a violation.
12	8.11	47			Y		Entry Point and Distribution excursions are
13	8.05				Y		Cumulative). An 'excursion' is any day in which the
14	8.07				Y		water quality parameter(s) fall below the minimum
15					OFF		set by the State
16					OFF		
17					OFF		
18	8.08				Y		
19	8.10				Y		
20	8.09	46			Y		
21	8.12				Y		
22	8.11				Y		
23	8.10				Y		
24	8.15				Y		
25	8.07				Y		
26					OFF		
27					OFF		
28	8.08	43			Y		
29					OFF		
30					OFF		
31					OFF		
=N=Excursion) Total N's					0		
						Print Name: Levi Beachy	
						Signature:	
						Date: June 2, 2025	

Minimum Water Quality  
Parameters as set by State:

pH	7.2	
Alk	30.0	(Alkalinity)

Send to DHS within 10 days after end of sampling period

OHA Drinking Water Program, PO Box 14350, Portland, OR 97293-0350

Phone (971) 673-0405 Website: <http://healthoregon.org/dwp/>