



Water Quality Parameter Monitoring Form
Lead & Copper Rule Corrosion Control

County: Tillamook

Agency: Region 1

ENTRY POINT

EP- D

Day	pH	Alk	Phos	Sili	Y/N	<< Have	System Name: Tillamook Water Dept, City of					
1					OFF	minimums						
2					OFF	been met	PWS ID: 41					
3					OFF	for this day?	0 0 8 9 3					
4	8.14	49			Y							
5					OFF							
6					OFF		Sample Period November, 2025					
7	7.64				Y		Month/Year					
8	7.69				Y							
9					OFF							
10					OFF	Number of excursions* during this month:	0					
11					OFF	<i>(Over 9 excursions in 6 months is a violation.</i>						
12	7.67	47			Y	<i>Entry Point and Distribution excursions are</i>						
13					OFF	<i>Cumulative). An 'excursion' is any day in which the</i>						
14					OFF	<i>water quality parameter(s) fall below the minimum</i>						
15					OFF	<i>set by the State</i>						
16					OFF							
17	7.69	47			Y							
18					OFF							
19					OFF							
20					OFF							
21					OFF	Minimum Water Quality						
22					OFF	Parameters as set by State:						
23					OFF							
24	7.66				Y	pH 7.2						
25	7.70	51			Y	Alk 30.0	(Alkalinity)					
26					OFF							
27					OFF							
28					OFF							
29					OFF							
30					OFF							
(N=Excursion) Total N's						0	Print Name:	Austin Harmon				
							Signature:					
						Date:	December 1, 2025					

Send to DHS within 10 days after end of sampling period

OHA Drinking Water Program, PO Box 14350, Portland, OR 97293-0350

Phone (971) 673-0405 Website: <http://healthoregon.org/dwp/>