



Water Quality Parameter Monitoring Form

Lead & Copper Rule Corrosion Control

County: Tillamook

Agency: Region 1

ENTRY POINT

EP- D

Day	pH	Alk	Phos	Sili	Y/N	<< Have minimums been met for this day?	PWS ID: 41	<input type="text" value="0"/> <input type="text" value="0"/> <input type="text" value="8"/> <input type="text" value="9"/> <input type="text" value="3"/>				
1					OFF							
2					OFF							
3					OFF							
4					OFF		System Name:	Tillamook Water Dept, City of				
5	7.50				Y							
6	7.48	39			Y		Sample Period	December, 2025				
7					OFF			Month/Year				
8	7.45				Y							
9					OFF							
10					OFF		Number of excursions* during this month:	0				
11					OFF		<i>(Over 9 excursions in 6 months is a violation.</i>					
12					OFF		<i>Entry Point and Distribution excursions are</i>					
13					OFF		<i>Cumulative). An 'excursion' is any day in which the</i>					
14					OFF		<i>water quality parameter(s) fall below the minimum</i>					
15	7.44	43			Y		<i>set by the State</i>					
16					OFF							
17					OFF							
18					OFF							
19					OFF							
20					OFF							
21	7.51	51			Y							
22					OFF							
23					OFF							
24					OFF							
25	7.48				Y							
26					OFF							
27	7.21	46			Y							
28					OFF							
29					OFF							
30					OFF		Print Name:	Austin Harmon				
31					OFF		Signature:					
=N=Excursion) Total N's					0		Date:	February 2, 2026				

System Name: Tillamook Water Dept, City of

Sample Period: December, 2025

Month/Year

Number of excursions* during this month: 0

(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are Cumulative). An 'excursion' is any day in which the water quality parameter(s) fall below the minimum set by the State

Minimum Water Quality Parameters as set by State:		
pH	<input type="text" value="7.2"/>	
Alk	<input type="text" value="30.0"/>	(Alkalinity)
	<input type="text"/>	

Print Name: Austin Harmon

Signature:

Date: February 2, 2026

Send to DHS within 10 days after end of sampling period
 OHA Drinking Water Program, PO Box 14350, Portland, OR 97293-0350
 Phone (971) 673-0405 Website: <http://healthoregon.org/dwp/>