



Water Quality Parameter Monitoring Form

Lead & Copper Rule Corrosion Control

County: Tillamook

Agency: Region 1

ENTRY POINT

EP- D

Day	pH	Alk	Phos	Sili	Y/N
1					OFF
2	7.21	49			Y
3	7.63				Y
4					OFF
5					OFF
6					OFF
7					OFF
8					OFF
9	7.70	43			Y
10					OFF
11					OFF
12					OFF
13					OFF
14					OFF
15					OFF
16					OFF
17					OFF
18					OFF
19	7.64	48			Y
20					OFF
21					OFF
22					OFF
23	7.26	49			Y
24					OFF
25					OFF
26					OFF
27					OFF
28					OFF
29					
30					
31					

<< Have minimums been met for this day?

PWS ID: 41 0 0 8 9 3

System Name: Tillamook Water Dept, City of

Sample Period: February, 2026  
Month/Year

Number of excursions\* during this month: 0  
( Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are Cumulative). An 'excursion' is any day in which the water quality parameter(s) fall below the minimum set by the State

Minimum Water Quality Parameters as set by State:

pH	7.2
Alk	30.0 (Alkalinity)

Print Name: Austin Harmon  
Signature:   
Date: March 10, 2026

=N=Excursion) Total N's 0

Send to DHS within 10 days after end of sampling period

OHA Drinking Water Program, PO Box 14350, Portland, OR 97293-0350

Phone (971) 673-0405 Website: http://healthoregon.org/dwp/