



Water Quality Parameter Monitoring Form

Lead & Copper Rule Corrosion Control

County: Tillamook

Agency: Region 1

Day	pH	Alk	Phos	Sili	Y/N	<< Have minimums been met for this day?	Distribution					
1					Y		PWS ID: 41	0	0	8	9	3
2					Y		System Name: Tillamook Water Dept, City of					
3					Y							
4					Y		Sample Period: September 2021 Month/Year					
5					Y							
6					Y							
7					Y							
8		37			Y							
9					Y							
10					Y		Number of excursions* during this month: 0					
11					Y		(Over 9 excursions in 6 months is a violation.					
12					Y		Entry Point and Distribution excursions are					
13					Y		Cumulative). An 'excursion' is any day in which the					
14					Y		water quality parameter(s) fall below the minimum					
15		49			Y		set by the State					
16					Y							
17					Y							
18					Y							
19					Y							
20		51			Y							
21					Y							
22					Y							
23					Y							
24					Y							
25					Y							
26					Y							
27		47			Y							
28					Y							
29					Y							
30					Y							
31					Y							
=N=Excursion) Total N's					0		Print Name: Levi Beachy					
							Signature:					
							Date: October 1, 2021					

Send to DHS within 10 days after end of sampling period

OHA Drinking Water Program, PO Box 14350, Portland, OR 97293-0350
Phone (971) 673-0405 Website: <http://healthoregon.org/dwp/>