



Water Quality Parameter Monitoring Form

Lead & Copper Rule Corrosion Control

County: Tillamook

Agency: Region 1

Day	pH	Alk	Phos	Sili	Y/N	<< Have minimums been met for this day?	Distribution					
1					Y		PWS ID: 41	0	0	8	9	3
2					Y		System Name: Tillamook Water Dept, City of					
3					Y							
4		48			Y		Sample Period	October 2021				
5					Y			Month/Year				
6					Y		Number of excursions* during this month: 0 (Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are Cumulative). An 'excursion' is any day in which the water quality parameter(s) fall below the minimum set by the State					
7					Y							
8					Y							
9					Y							
10					Y							
11		56			Y							
12					Y							
13					Y							
14					Y							
15					Y							
16					Y		Minimum Water Quality Parameters as set by State: pH 7.2 Alk 30.0 (Alkalinity)					
17					Y							
18		32			Y							
19					Y							
20					Y							
21					Y							
22					Y							
23					Y							
24					Y							
25		51			Y							
26					Y		Print Name: Levi Beachy Signature: Date: November 1, 2021					
27					Y							
28					Y							
29					Y							
30					Y							
31					Y							
=N=Excursion) Total N's					0							

Send to DHS within 10 days after end of sampling period

OHA Drinking Water Program, PO Box 14350, Portland, OR 97293-0350

Phone (971) 673-0405 Website: <http://healthoregon.org/dwp/>