

Water Quality Parameter Monitoring Form  
**Lead & Copper Rule Corrosion Control**

County: Tillamook

Agency: Region 1

Day	Sample Location	pH	Alk	PO4	Other	Y/N	<< Have minimums been met for this day?	Distribution						
1						Y								
2						Y								
3	210 Laurel Ave		33			Y		PWS ID: 41	0	0	8	9	3	
4						Y		System Name:	Tillamook Water Dept, City of					
5						Y		Sample Period	January 2022					
6						Y			Month/Year					
7						Y								
8						Y								
9						Y								
10						Y		Number of excursions* during this month:	0					
11						Y		( Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are Cumulative). An 'excursion' is any day in which the water quality parameter(s) fall below the minimum set by the State						
12	210 Laurel Ave	7.31	23			Y								
13						Y								
14						Y								
15						Y								
16						Y								
17						Y								
18						Y								
19	210 Laurel Ave	7.51	25			Y								
20						Y								
21						Y								
22						Y								
23						Y								
24						Y								
25						Y								
26	210 Laurel Ave	8.07	29			Y								
27						Y								
28						Y								
29						Y								
30						Y		Print Name: ,	Levi Beachy					
31						Y		Signature:						
						(No=N=Excursion) Total N's	0	Date:	February 1, 2022					

**Minimum Water Quality Parameters as set by State:**

pH	7.2	
Alk	30.0	(Alkalinity)

Send to DHS within 10 days after end of sampling period

OHA Drinking Water Program, PO Box 14350, Portland, OR 97293-0350  
 Phone (971) 673-0405 Website: <http://healthoregon.org/dwp/>