

Water Quality Parameter Monitoring Form
Lead & Copper Rule Corrosion Control

County: Tillamook

Agency: Region 1

Day	Sample Location	pH	Alk	PO4	Other	Y/N	<< Have minimums been met for this day?	Distribution						
1						Y								
2	210 Laurel Ave	7.88	37			Y		PWS ID: 41	0	0	8	9	3	
3						Y								
4						Y		System Name:	Tillamook Water Dept, City of					
5						Y		Sample Period	February 2022					
6						Y			Month/Year					
7	210 Laurel Ave	8.31	30			Y								
8						Y								
9						Y								
10						Y		Number of excursions* during this month:	0					
11						Y		<i>(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are Cumulative). An 'excursion' is any day in which the water quality parameter(s) fall below the minimum set by the State</i>						
12						Y								
13						Y								
14						Y								
15						Y								
16	210 Laurel Ave	7.83	27			Y								
17						Y								
18						Y								
19						Y								
20						Y								
21						Y								
22	210 Laurel Ave		60			Y								
23						Y								
24						Y								
25						Y								
26						Y								
27						Y								
28						Y								
29						Y								
30						Y		Print Name:	Levi Beachy					
31						Y		Signature:						
								Date:	March 9, 2022					
								(No=N=Excursion) Total N's	0					

Minimum Water Quality Parameters as set by State:

pH	7.2	
Alk	30.0	(Alkalinity)

Send to DHS within 10 days after end of sampling period

OHA Drinking Water Program, PO Box 14350, Portland, OR 97293-0350
 Phone (971) 673-0405 Website: <http://healthoregon.org/dwp/>