



Water Quality Parameter Monitoring Form
Lead & Copper Rule Corrosion Control

County: Tillamook

Agency: Region 1

Day	Sample Location	pH	Alk	PO4	Other	Y/N
3	Well 2	7.33	20			Y
3	Well 3	7.52	23			Y
3	210 Laurel Ave	7.71	19			Y
16	Well 2	7.60	65			Y
16	Well 3	7.77	21			Y
16	210 Laurel Ave	7.63	18			Y
23	Well 2	7.83	21			Y
23	Well 3	7.78	21			Y
23	210 Laurel Ave	7.64	21			Y
31	Well 2	7.44	21			Y
31	Well 3	7.77	23			Y
31	210 Laurel Ave	7.60	22			Y

<< Have
 minimums
 been met
 for this day?

Distribution

PWS ID: 41

0	0	8	9	3
---	---	---	---	---

System Name: Tillamook Water Dept, City of

Sample Period May 2022
 Month/Year

Number of excursions* during this month: 0
 (Over 9 excursions in 6 months is a violation.
 Entry Point and Distribution excursions are
 Cumulative). An 'excursion' is any day in which the
 water quality parameter(s) fall below the minimum
 set by the State

**Minimum Water Quality
 Parameters as set by State:**

pH	7.2	
Alk		(Alkalinity) Monitoring

Print Name: Levi Beachy
Signature:

Date: June 9, 2022

(No=N=Excursion) Total N's **0**

Send to DHS within 10 days after end of sampling period

OHA Drinking Water Program, PO Box 14350, Portland, OR 97293-0350
 Phone (971) 673-0405 Website: <http://healthoregon.org/dwp/>