



Water Quality Parameter Monitoring Form  
**Lead & Copper Rule Corrosion Control**

County: Tillamook

Agency: Region 1

Day	Sample Location	pH	Alk	PO4	Other	Y/N
5	Well 2	7.79	22			Y
5	Well 3	7.87	20			Y
5	210 Laurel Ave	7.61	20			Y
20	Well 2	7.45	26			Y
20	Well 3	7.76	27			Y
20	210 Laurel Ave	7.79	21			Y
29	Well 2	7.53	46			Y
29	Well 3	7.52	47			Y
29	210 Laurel Ave	7.77	27			Y

<< Have  
 minimums  
 been met  
 for this day?

**Distribution**

PWS ID: 41

System Name: Tillamook Water Dept, City of

Sample Period: June 2022  
 Month/Year

Number of excursions\* during this month:   
 ( Over 9 excursions in 6 months is a violation.  
 Entry Point and Distribution excursions are  
 Cumulative). An 'excursion' is any day in which the  
 water quality parameter(s) fall below the minimum  
 set by the State

**Minimum Water Quality  
 Parameters as set by State:**

pH   
 Alk  (Alkalinity)  
 Monitoring

Print Name: Levi Beachy

Signature:

Date: July 5, 2022

(No=N=Excursion) Total N's

Send to DHS within 10 days after end of sampling period

OHA Drinking Water Program, PO Box 14350, Portland, OR 97293-0350

Phone (971) 673-0405 Website: <http://healthoregon.org/dwp/>