



Water Quality Parameter Monitoring Form  
**Lead & Copper Rule Corrosion Control**

County: Tillamook

Agency: Region 1

Day	Sample Location	pH	Alk	PO4	Other	Y/N
10	Well 2	7.27	70			Y
10	210 Laurel Ave	7.61	23			Y
15	Well 2	7.32	45			Y
15	210 Laurel Ave	7.46	47			Y
22	Well 2	7.40	46			Y
22	210 Laurel Ave	7.37	37			Y
30	Well 2	7.21	79			Y
30	210 Laurel Ave	7.39	37			Y

<< Have  
 minimums  
 been met  
 for this day?

**Distribution**

PWS ID: 41

**System Name:** Tillamook Water Dept, City of

**Sample Period:** September 2022  
 Month/Year

**Number of excursions\* during this month:** 0  
 ( Over 9 excursions in 6 months is a violation.  
 Entry Point and Distribution excursions are  
 Cumulative). An 'excursion' is any day in which the  
 water quality parameter(s) fall below the minimum  
 set by the State

**Minimum Water Quality  
 Parameters as set by State:**

pH   
 Alk  (Alkalinity)  
 Monitoring

**Print Name:** Levj Beachy

**Signature:**

**Date:** October 4, 2022

(No=N=Excursion) Total N's

Send to DHS within 10 days after end of sampling period

OHA Drinking Water Program, PO Box 14350, Portland, OR 97293-0350

Phone (971) 673-0405 Website: <http://healthoregon.org/dwp/>